

Missouri Department of dnr.mo.gov

NATURAL RESOURCES

Eric R. Greitens, Governor

Carol S. Comer, Director

September 22, 2017

New Harmony Baptist Church
Mr. Matt Milligan
PO Box 724
Salem, MO 65560

Dear Mr. Milligan:

The New Harmony Baptist Church public water system (ID # MO4172690, Dent Co.) has had multiple violations of monitoring requirements and drinking water standards from July 2012 through November 2012. During this time period this system incurred one maximum contaminant level violation for total coliform bacteria and three monitoring violations. Public notice is required for all of these violations, but has not been reported for any of them.

The Missouri Department of Natural Resources has asked the Midwest Assistance Program (MAP) to contact you and offer assistance. MAP is a not-for-profit organization that provides technical assistance, on-site consultation, and training to public water systems with potential violation/health concerns and/or violations, at no cost to you. We have referred your system to MAP for outreach, based on concerns with your public notification procedure violations, and the potential for additional violation notifications.

MAP staff will be contacting you in the near future. Their offer of assistance will include a Technical, Managerial and Financial Assessment to determine the areas in which your system could benefit from technical assistance, with a specific emphasis on resolving the current public notification violations and preventing future issues.

MAP does not work for the Department and has no regulatory authority. MAP can only provide assistance to systems and communities interested in benefiting from their services. Additional information about MAP and the services they provide can be found at www.map-inc.org or you can contact MAP's Regional Field Manager Mr. Chris Jewett by phone at 641-799-8532, or by email at cjewett@map-inc.org.

Enclosed you will find new copies of the missing public notice and certification forms. If you have questions about this letter or your violation status, please contact Ms. Danielle West at the Missouri Department of Natural Resources, Water Protection Program, Public Drinking Water Branch, P.O. Box 176, Jefferson City, MO 65102-0176, by phone at 573-522-5027, or by email at danielle.west@dnr.mo.gov. Thank you.

Sincerely,

WATER PROTECTION PROGRAM

Diane Vitello
Capacity Development & Source Water Protection Unit Chief

DV:jl


Enclosure

c: Mr. Dave Dirks, Midwest Assistance Program
Southeast Regional Office

Dave Dirks
573-276-8918



Recycled paper



**Missouri Department Of Natural Resources
Public Drinking Water Program
P.O. Box 176
Jefferson City, MO 65102 (573)751-5331**

Public Water System Bacteriological Report

PWS Name :	NEW HARMONY BAPTIST CHURCH	PWS ID :	MO4172690
Mail to :	TERRY BERRY	County :	DENT
	5841 WEST HWY 32		
	PO BOX 724		Please notify us of any name and address changes
	SALEM, MO 65560		

Date Collected :	Collector :	Sample Type :
10/18/2012	JS	Repeat
Lab Sample ID :	Location Name:	Location ID:
43229	ED WING LRLVL MOP SI	03
		Lab Results :
		P

Sample tested positive for total coliform. This positive sample may require follow up samples to be collected. Please contact your local regional office at 573-840-9750 for further sampling instructions.

Date Collected :	Collector :	Sample Type :
10/18/2012	JS	Repeat
Lab Sample ID :	Location Name:	Location ID:
43171	ED WING LRLVL MOP SI	03
		Lab Results :
		P

Sample tested positive for total coliform. This positive sample may require follow up samples to be collected. Please contact your local regional office at 573-840-9750 for further sampling instructions.


Date Collected :	Collector :	Sample Type :
10/18/2012	JS	Repeat
Lab Sample ID :	Location Name:	Location ID:
43168	ED WING LRLVL MOP SI	03
		Lab Results :
		P

Sample tested positive for total coliform. This positive sample may require follow up samples to be collected. Please contact your local regional office at 573-840-9750 for further sampling instructions.

Date Collected :	Collector :	Sample Type :
10/18/2012	JS	Triggered
Lab Sample ID :	Location Name:	Location ID:
43203		WL 17264
		Lab Results :
		A

Coliform absent. Sample considered safe.

Note to public water systems: If you take a routine sample from a well rather than your distribution system, a violation may be issued by Missouri Public Drinking Water Branch.



MISSOURI
DEPARTMENT OF
NATURAL RESOURCES

**Instructions for Multiple Month Public Notice:
Transient Non-community Systems**

Date Public Must be Notified by: Within 30 days of receipt

Date to send Documentation back to the Missouri Department of Natural Resources by: Within seven days of notifying the public

Overview: Public water systems must provide public notice in a form and manner reasonably calculated to reach persons served in the required time period. The Department provides these instructions and sample notice (next page) to help systems comply with the Public Notice Rule and ensure the public is duly notified. Public water systems must take the following actions:

- A. Post the notice in logical places, plus at least one additional method; and
 - B. Report to the Department how and when this water system notified its customers.
- A. The water system must begin notifying consumers of these violations. Use the following methods:
1. Post the notice. This may include water fountains, spigots and post-mix machines. Doors, the cash register and bulletin boards, etc. are also logical places. Posting must be on-going for as long as the violation exists. For violations that have been resolved, the minimum posting period is seven days; and
 2. Use at least one additional method. Transient non-community systems typically make copies available to all who request one. For camps, etc., the Department strongly recommends the system provide parents or guardians of minors with a copy of the notice.
- B. **AFTER** the water system has notified the public, send a copy of the system's version of the public notice **and** the completed certification below to:

Department of Natural Resources
Water Protection Program
Public Drinking Water Branch
Attn: Public Notice Coordinator
P.O. Box 176
Jefferson City, MO 65102-0176

YOU MUST SEND PUBLIC NOTICE DOCUMENTS TO THE DEPARTMENT TO FULFILL THIS REQUIREMENT. Otherwise your system will receive another violation. Please send this documentation to us within one week after posting. You may fax these documents to 573-751-3110. Please retain a copy of the completed certification and the public notice for a minimum of three years. Complete state regulations for the public notification of drinking water violations can be found in 10 CSR 60-8.010 <http://s1.sos.mo.gov/cmsimages/adrules/csr/current/10csr/10c60-8.pdf>

CERTIFICATION

I certify this public water system notified the people it serves by the methods indicated below:

1. Posting:
 Begin Posting Date: Oct 2 2017
 End Posting Date: Oct 9 2017 (minimum posting period of seven days)
 Locations: Church main bulletin boards
and church website
 If this system maintains a website, please post there as well.

- And** -----
2. Copy made available or Mail or hand delivery or E-mail
 Date(s): Oct 2 2017 Date(s): Oct 9 2017 Date(s): _____
 Or other: _____

Matt May
(Signature)

Associate Pastor
(Title)

10-2-17
(Date)

PWS ID #: MO4172690

System Name: New Harmony Baptist Church

County: Dent